

3.0 CARICHI TERMICI INVERNALI

RIEPILOGO DISPERSIONI						
GLOBALE EDIFICIO	3076.5	4539.2	0.678	0.289	0.617	84807
Appart/zona/ambiente	A	volume	S/V	Cdr	Cdl	dispers
Piano/Scala: 01 INTERRATO						15700
0101 REC 1	346.5	496.8	0.697			6013
01 PALESTRA	346.50	496.80	0.697			6132
0102 REC 2	49.3	147.9	0.333			2066
01 SALA CORSI	49.30	147.90	0.333			2172
0103 REC 3	319.0	759.0	0.420			7622
01 MAGAZZINO PALESTRA	7.50	22.50	0.333			22
02 RECEPTION	43.53	97.29	0.447			1401
03 SPOGLIATOIO ADDETTI	24.87	25.11	0.990			219
04 WC H	10.70	13.20	0.811			95
05 RIPOSTIGLIO	5.40	16.20	0.333			15
06 SPOGLIATOIO MASCHILE	41.90	98.70	0.425			2025
07 DOCCE 1	12.96	38.88	0.333			102
08 BAGNO TURCO 1	6.21	18.63	0.333			47
09 WC 1	4.05	12.15	0.333			11
10 SPOGLIATOIO FEMMINILE	29.70	89.10	0.333			1757
11 DOCCE 2	12.96	38.88	0.333			91
12 BAGNO TURCO 2	6.21	18.63	0.333			47
13 WC 2	4.05	12.15	0.333			11
14 INFERMERIA	24.16	38.28	0.631			556
15 WC 3	6.60	19.80	0.333			48
16 DISIMPEGNO	12.84	27.72	0.463			427
17 MAGAZZINO RISTORANTE	17.28	51.84	0.333			124
18 SPOGLIATOIO ADDETTI MAS	13.44	40.32	0.333			508
19 DOCCE	4.68	14.04	0.333			39
20 WC 4	7.02	21.06	0.333			49
21 SPOGLIATOIO ADDETTI FEM	18.66	31.68	0.589			541
22 DOCCE	4.29	12.87	0.333			35
Piano/Scala: 02 SEMINTERRATO						13936
0201 REC 4	95.6	211.7	0.452			4917
01 CONFERENCE ROOM	95.56	211.65	0.452			5154
0202 REC 5	207.4	577.8	0.359			9019
01 BAR	61.95	290.82	0.213			6575
02 DISPENSA	0.00	45.00	0.000			351
03 DISTRIBUZIONE	6.60	35.52	0.186			479
04 MAGAZZINO	0.00	12.87	0.000			19
05 WC	21.30	57.72	0.369			215
06 DISIMPEGNO	12.15	22.95	0.529			532
07 SPOGLIATOI ADDETTI	27.40	26.40	1.038			471

3.0 CARICHI TERMICI INVERNALI

Appart/zona/ambiente		A	volume	S/V	Cdr	Cdl	dispers
08	UFFICIO	48.29	60.27	0.801			897
09	ARCHIVIO	29.75	26.25	1.133			215

Piano/Scala: 03		RIALZATO					24031
0301 REC 6		504.3	719.2	0.701			20748
01	RISTORAZIONE	398.23	588.60	0.677			17342
02	INGRESSO	15.66	24.48	0.640			600
03	PRIVE	90.39	106.08	0.852			3044
0302 REC 7		73.7	142.5	0.517			1342
01	CUCINA	73.65	142.45	0.517			1425
0303 REC 8		78.9	104.3	0.756			1942
01	DISTRIBUZIONE	16.97	31.11	0.545			1086
02	WC 1	44.50	48.00	0.927			560
03	WC 2	17.40	25.20	0.690			371

Piano/Scala: 04		SPOGLIATOI					31139
0401 ALLOGGIO CUSTODE		137.5	132.0	1.042			1802
01	ALLOGGIO CUSTODE 1	61.50	54.00	1.139			689
02	ALLOGGIO CUSTODE 2	48.00	54.00	0.889			550
03	WC H 2	28.00	24.00	1.167			563
0402 SPOGLIATOI CALCIO A 7		614.7	606.2	1.014			14275
01	SPOGLIATOIO 1.1	63.92	65.28	0.979			1367
02	DOCCE 1	16.80	16.20	1.037			575
03	DISIMPEGNO 1	8.00	12.00	0.667			185
04	WC H 3	13.20	10.80	1.222			407
05	SPOGLIATOIO 1.2	63.92	65.28	0.979			1367
06	SPOGLIATOIO 2.1	63.92	65.28	0.979			1367
07	DOCCE 2	16.80	16.20	1.037			575
08	DISIMPEGNO 2	8.00	12.00	0.667			185
09	WC H 4	13.20	10.80	1.222			407
10	SPOGLIATOIO 2.2	63.92	65.28	0.979			1367
11	SPOGLIATOIO 3.1	63.92	65.28	0.979			1367
12	DOCCE 3	16.80	16.20	1.037			575
13	DISIMPEGNO 3	8.00	12.00	0.667			185
14	WC H 5	13.20	10.80	1.222			407
15	SPOGLIATOIO 3.2	63.92	65.28	0.979			1367
16	WC 3	15.50	12.00	1.292			475
17	SPOGLIATOIO ARBITRO 1	34.70	36.75	0.944			716
18	WC H 6	21.90	13.50	1.622			572
19	INFERMERIA	45.10	35.25	1.279			812
0403 SPOGLIATOI CALCIO A 11		649.6	641.9	1.012			15062
01	SPOGLIATOIO 1.1	98.16	80.64	1.217			1914

3.0 CARICHI TERMICI INVERNALI

Appart/zona/ambiente		A	volume	S/V	Cdr	Cdl	dispers
02	DOCCE 4	16.80	16.20	1.037			575
03	DISIMPEGNO 4	8.00	12.00	0.667			185
04	WC H 7	13.20	10.80	1.222			407
05	SPOGLIATOIO 1.2	78.96	80.64	0.979			1723
06	SPOGLIATOIO 2.1	78.96	80.64	0.979			1723
07	DOCCE 5	16.80	16.20	1.037			575
08	DISIMPEGNO 5	8.00	12.00	0.667			185
09	WC H 8	13.20	10.80	1.222			407
10	SPOGLIATOIO 2.2	78.96	80.64	0.979			1723
11	SPOGLIATOIO 3.1	78.96	80.64	0.979			1723
12	DOCCE 6	16.80	16.20	1.037			568
13	DISIMPEGNO 6	8.00	12.00	0.667			185
14	WC H 9	13.20	10.80	1.222			407
15	SPOGLIATOIO 3.2	71.44	72.96	0.979			1572
16	WC 4	15.50	12.00	1.292			475
17	SPOGLIATOIO ARBITRO 2	34.70	36.75	0.944			716